

Government of Bihar
Public Health Engineering Department

DISTRICT-EAST CHAMPARAN

SUB DIVISION - CHAKIA

MONTH-JUNE- 2023

SL. NO	BLOCK	PANCHAYAT	VILLAGE	LOCATION	PARAMETERS								
					PH	EC	TDS	Fe	Alka	NO3	Turb	SO4	Rema
1	KALYANPUR	PAKARIDIXIT	MADHOPUR	ARPA INTERNATIONAL SCHOOL	7.2	415	270	0.2	140	BDL	1	NT	
Desirable Limit					6.5-8.5	-	500 mg/l	1.0 mg/l	200 mg/l	45	1 NTU	200 mg/l	
permissible Limit * in Absence of Alternate source					NR	-	2000mg/l	NR	600 mg/l	NR	5 NTU	400 mg/l	

Vinod Chy
21/06/23
SUB DIVISION CHEMIST

Indira
22/06/2023
SDO